

RAKESH BHATIA & ASSOCIATES

B.E.(Civil), H.U.D.A. & M.C.F. EMPANELED , ENGINEER B.E -7378

FIRST IN MERIT

Structure Engg., Consulting Engineer

Office-Cum -Resi.:1-D/129, N.I.T. Faridabad

BUILDING SAFETY CERTIFICATE

I had visited M/S Sant Nirankari Public School (Sector 16 A Faridabad) Dated 10.01.2023

The school building is a L shaped building consists of Ground Floor, First Floor, Second Floor & Verandha in front of it. The School building is a RCC framed structure with RCC slab & beams.

There is a RCC Basements and shed being used as a multipurpose activity hall.

As per my directions & instructions the Rebound hammer test on columns & Ultrasonic Pulse Velocity Test has been carried out on slab.

As per the test report the building is structurally safe & sound. The IS standards & N.B.C norms are being followed.

The design has been checked & found as per N.B.C. Norms & I.S Standard.

The school building as on today is structurally safe & sound. *for 2 yrs*

ER. RAKESH BHATIA

R Bhatia
20/01/2023

Rakesh Bhatia & Associates
B.E. Civil A.I.V., H.U.D.A (Regd.)
Structural Designer & Consulting Engineer
1D-129, N.I.T. FARIDABAD